

Table of setting of valves at the manifolds

Circuit	1	2	3	4	5	6
Setting	2,92	6 (open)	6 (open)	2,85	2,85	2,83

Circuit	7	8	9	10	11
Setting	2,83	2,83	2,83	2,85	2,88


Table of rooms - 1. floor

No.	Room	Area [m <sup>2</sup> ]
2.01	corridor	31,20
2.02	office	13,62
2.03	office	11,70
2.04	office	12,39
2.05	office	18,78
2.06	office	21,65
2.07	office	14,74
2.08	office	15,24
2.09	kitchen	3,49
2.10	WC men	5,81
2.11	WC women	3,37

Table of radiators - first floor

No.	Radiators	Capacity[W]
2.02	RADIK 22 VK (600/1200)	593
2.09	RADIK 11 VK (400/400)	114
2.10	RADIK 22 VK (900/1200)	911
2.11	RADIAL PLAN VERTIKAL - M10 (1800/6000)	326

± 0,000 = 153 m.a.s.l.



Student Aneta Burešová	Bachelor thesis supervisor Ing. Daniel Adamovský, Ph.D.	Academic year 2015-2016	Faculty of civil engineering <b>CTU</b>
Bachelor project - Department of Microenvironmental and Building Services Engineering			
Name <b>Heating system with renewable energy sources</b>		Date 5/2016	
		Scale M 1:50	
		Number 2	
Attachment <b>HEATING SYSTEM - FIRST FLOOR</b>			Consultant