



**Czech Technical University in Prague
Faculty of Electrical Engineering
Department of Economics, Management and Humanities**

Decentralized electricity supplies of village behind the polar circle

Master's thesis

Study program: Electrical engineering, power engineering and management

Field of study: Economy and management of power engineering

Scientific advisor: Ing. Julius Bemš, PhD

Bc. Alena Surovezhko

Prague 2018



ZADÁNÍ DIPLOMOVÉ PRÁCE

I. OSOBNÍ A STUDIJNÍ ÚDAJE

Příjmení **Surovezhko** Jméno **Alena** Osobní číslo: **442876**
Fakulta/ústav **Fakulta elektrotechnická**
Zadávající katedra/ústav **Katedra ekonomiky, manažerství a humanitních věd**
Studijní program **Elektrotechnika, energetika a management**
Studijní obor **Ekonomika a řízení energetiky**

II. ÚDAJE K DIPLOMOVÉ PRÁCI

Název diplomové práce

Decentralized electricity supplies of village behind the polar circle.

Název diplomové práce anglicky:

Decentralized electricity supplies of village behind the polar circle.

Pokyny pro vypracování:

- Describe technical background of possible technologies.
- Design the decentralized electric supply in remote area.
- Prepare financial model for project evaluation.
- Compare possible project scenarios and provide sensitivity analysis.

Seznam doporučené literatury:

- Subhes C. - Energy Economics: Concepts, Issues, Markets and Governance, Springer, 2011, ISBN: 0857292676.
- R. A. Brealey, S. C. Myers, and F. Allen, Principles of Corporate Finance, 10th ed. McGraw-Hill/Irwin, 2010.
- Vissarionov V.I., Deryugina G.V., Kuznetsova V.A., Solar Power Engineering: Book for Higher Educational Institutions / Ed. by V.I. Vissarionov -M., Publishing house MPEI, 2008. - 320p.

Jméno a pracoviště vedoucí(ho) diplomové práce:

Ing. Jůlius Bemš, Ph.D., FEL ČVUT v Praze, K 13116

Jméno a pracoviště druhé(ho) vedoucí(ho) nebo konzultanta(ky) diplomové práce:

Datum zadání diplomové práce: **26.01.2018**

Termín odevzdání diplomové práce: _____

Platnost zadání diplomové práce: **30.09.2019**

Ing. Jůlius Bemš, Ph.D.
podpis vedoucí(ho) práce

podpis vedoucí(ho) ústavu/katedry

prof. Ing. Pavel Ripka, CSc.
podpis děkana/kvi

III. PŘEVZETÍ ZADÁNÍ

Diplomantka bere na vědomí, že je povinna vypracovat diplomovou práci samostatně bez cizí pomoci s výjimkou poskytnutých konzultací.
Seznam použité literatury, jiných pramenů a jmen konzultantů je třeba uvést v diplomové práci.

Datum převzetí zadání

Podpis studentky

Topic registration form

Student: Alena Surovezhko

Study program: Electrical engineering, power engineering and management

Topic: Decentralized electricity supplies of village behind the polar circle.

Guidelines:

- Describe technical background of possible technologies
- Design the decentralized electric supply in remote area
- Prepare financial model for project evaluation
- Compare possible project scenarios and provide sensitivity analysis

Literature for registration:

1. Vissarionov V.I., Deryugina G.V., Kuznetsova V.A., Solar Power Engineering: Book for Higher Educational Institutions / Ed. by V.I.Vissarionov -M.: Publishing house MPEI, 2008. - 320p.
2. Subhes C. - Energy Economics: Concepts, Issues, Markets and Governance, Springer, 2011, ISBN: 0857292676.
3. R. A. Brealey, S. C. Myers, and F. Allen, Principles of Corporate Finance, 10th ed. McGraw-Hill/Irwin, 2010.

Declaration:

I hereby declare that this master's thesis is the product of my own independent work and that I have clearly stated all information sources used in the thesis according to Methodological Instruction No. 1/2009 – "On maintaining ethical principles when working on a university final project, CTU in Prague".

Date

Signature

Abstract

Nowadays scientists more and more talk about the shortage of hydrocarbons. And possible solution of this problem is using of alternative energy sources, since the lack of natural resources will inevitably lead to gradual increasing in energy prices. Moreover, in Russia remote areas without central power supply take about 70% of the country's territory with a population of up to 23 million people, where only diesel generators with using fuel are operated. In this case applying of alternative energy sources can be solution of the problem with lack of central power supply and with fuel savings.

The key factor in this work is the problem of object's power supply, which is remote from central power supply and which is located close to polar circle, where Midnight Sun presents. It can be solved using solar energy.

To achieve the goal of remote object power supplying, it is necessary to solve the following tasks:

- Calculate solar radiation of that are;
- Choose necessary equipment for photovoltaic power plant;
- Design of schematic diagram of the photovoltaic power plant;
- Estimate economic efficiency of solar energy sources implementation.

The results obtained in the project can be used to solve the similar tasks of remote objects power supply.

Key words

Renewable energy sources, photovoltaic power plant, polar circle, Midnight Sun, remote area, fuel savings.

Contents

| | |
|--|----|
| Abstract | 5 |
| Key words..... | 5 |
| List of abbreviations | 8 |
| Introduction | 9 |
| Chapter 1..... | 10 |
| Technical and climatic features of the investigated object | 10 |
| 1.1 Investigated object, characteristics, power supply requirements | 10 |
| 1.2 Climatic features of the investigated object | 11 |
| 1.3 Diesel power plant characteristics | 13 |
| 1.4 Consumer load graphs..... | 14 |
| Chapter 2..... | 17 |
| Potential assessment of renewable solar energy for investigated region..... | 17 |
| 2.1 The classical theoretical calculation of solar radiation | 17 |
| 2.2 Structural diagram of the power supply system | 23 |
| Chapter 3..... | 24 |
| Design of photovoltaic power station for the village behind the polar circle | 24 |
| 3.1 Choice of solar modules | 24 |
| 3.2 Choice of accumulator batteries | 27 |
| 3.3 Choice of solar controllers..... | 30 |
| 3.4 Choice of inverters | 30 |
| 3.5 Schematic diagram of the Photovoltaic Power Plant..... | 32 |
| Chapter 4..... | 33 |
| Financial model | 33 |
| 4.1 Theoretical background | 33 |
| 4.2 Economic parameters | 35 |
| 4.3 Financial model | 36 |
| Chapter 5..... | 38 |
| Financial analysis..... | 38 |
| 5.1 Sensitivity analysis..... | 38 |
| 5.2 Dependence NPV on discount rate | 38 |
| 5.3 Dependence NPV on electricity price..... | 39 |
| 5.4 Dependence NPV on useful life of solar panels | 39 |
| 5.5 Dependence NPV on escalation | 40 |
| Chapter 6..... | 41 |

| | |
|--|----|
| Comparative analysis of two power supply system operations | 41 |
| 6.1 Diesel generators power supply..... | 41 |
| 6.2 Power supply from photovoltaic panels and diesel generators..... | 42 |
| Chapter 7 | 44 |
| Scenarios | 44 |
| 7.1 Optimistic scenario..... | 44 |
| 7.2 Pessimistic scenario..... | 46 |
| Conclusion | 50 |
| Bibliography and references | 52 |
| Appendices..... | 55 |

List of abbreviations

DPP – Diesel Power Plant

DG – Diesel generator

USSR - Union of Soviet Socialist Republics

PVP - Photovoltaic panels

DC – Direct current

AC – Alternative current

SP – Solar panel

SC – Solar controller

ACB - Accumulator battery

I – Inverter

L – Load

C - Controller

AGM - Absorbent Glass Mat

NPV - Net Present Value

IRR - Internal Rate of Return

PI – Profitability Index

PP – Payback Period

Introduction

Nowadays in Russia remote areas without central power supply take about 70% of the country's territory with a population of up to 23 million people, where only diesel generators with using fuel are operated. And delivery of fuel to these remote areas is quite complicated, because rail roads are absent somewhere and usual roads can be not available because of snowpack. In this case, the fuel can be delivered only by helicopter that in turn has big influence on the final price of fuel. In addition, there is an increase in the tariffs of energy supply companies. Therefore the price for 1 kWh is about 100 RUB in remote areas, when the price in regular areas is about 4 RUB per 1 kWh now. Moreover, there are some risks, which also have influence on electricity power supply. It is fuel delivery and fuel discharge, because the weather is unpredictable on Far North. So, the use of alternative energy sources, especially solar energy can be a solution of this problem.

In this diploma thesis attention is focused on solar energy, in case of climatic feature of that area - the presence of a Midnight sun. The midnight sun lasts from 9th of May to 4th of August. Renewable energy is dynamically developing from technological and economic points and is being introduced around the world in modern world. Advantage of solar energy is obvious: sunlight is available anywhere in the world.

The purpose of the project is to develop the decentralized power supply system of a small village located in the territory behind the polar circle and prepare economic evaluation of decisions.

Throughout the work a reader will face the following structure. The thesis starts with providing information about technical and climatic features of the investigated object. After potential assessment of renewable solar energy for investigated region is presented. This part includes calculations of solar radiation in that area using two methods to confirm results. When data of solar radiation are got, it is possible to calculate parameters of needed equipment for solar power plant, choose it and to design schematic diagram of the photovoltaic power plant. So, the reader can find this information in Chapter 3. Feasibility study will be given in the Finance model part and methodology for economic evaluation will be described next. Finally, in order to show expedience and sustainability of the work sensitivity analysis and comparative analysis of two power supply system operations will be provided. In turn I should also mention that energy economics is complex because of a number of factors [1]:

- The constituent industries tend to be highly technical in nature, requiring some understanding of the underlying processes and techniques for a good grasp of the economic issues.
- Each industry of the sector has its own specific features which require special attention.
- Energy being an ingredient for any economic activity, its availability or lack of it affects the society and consequently, there are greater societal concerns and influences affecting the sector.
- The sector is influenced by interactions at different levels (international, regional, national and even local), most of which go beyond the subject of one discipline.

The results will be discussed in the end.

Chapter 1

Technical and climatic features of the investigated object

1.1 Investigated object, characteristics, power supply requirements

The main goal of this work is the development of decentralized power supply system for the small village located in the territory behind the polar circle. Lack of large manufacturing, as well as the features of geographical location excludes the possibility of centralized power supply.

One of the most perspective directions of energy development in modern conditions is the integration of local renewable energy resources for energy purposes. Basically, it is the integration of combined solar-diesel power plant that combine renewable energy installations and diesel power plants (DPP). Moreover, climatic and territorial features of the village allow us to use alternative energy sources.

The investigated object is a small Popigay village in the territory behind the polar circle nearby to Khatanga village. Khatanga village is located in the Taimyr Dolgano-Nenetsk area of Krasnoyarsk region, and its coordinates are: $71^{\circ} 59' \text{N}$, $102^{\circ} 30' \text{E}$. (Picture 1). It is 2.2 thousand km from the Khatanga village to the Krasnoyarsk regional center.

Popigay's installed energy production capacity is 100 kW, as the population of the village is 357 people. There is an elementary boarding school, a midwife office, a shop, a branch of the Federal post office of the Krasnoyarsk region, a rural house of culture, a library, a community of the Popigay KMN in the village [2].



Picture 1 - Location of the investigated object [2]

The category of village power supply reliability is the third one. For electrical receivers of the III category, electricity can be supplied from a single power source, on condition that the power supply interruptions must be repaired or the damaged power supply system element must be replaced do not

exceed 1 day [3]. But since an alternative energy source depends on climatic conditions, it is also necessary to provide a reliable source of electricity - DPP.

1.2 Climatic features of the investigated object

The main climatic feature of this village is the presence of a midnight sun and a polar night. The polar night at the Khatanga latitude lasts from 17th of November to 25th of January, the midnight sun lasts from 9th of May to 4th of August.

The polar night does not necessarily mean total darkness for all 24 hours. Its main feature is that the Sun does not rise above the horizon.

Since this village is below 72° 34'N, the polar night is nautical, i.e. at the time of the upper solstice twilight is observed. If we consider the whole polar night, then every day there are all types of twilight and periods without them [4].

The Sun angle under the horizon is from 6° 50' to 12° in nautical twilight.

Using the specialized program Solar Calculator [5], it is possible to determine the duration of the day or night, the angle of the sun's declination relative to the horizon for any day during the year (Picture 2 and Picture 3).

Picture 2 - Duration of the day during midnight sun [5]

It can be seen on these pictures, that we fill out next parameters: investigated city, the day of observation, the coordinates of object like latitude and longitude. After that the program gives us next calculated values, like: sun's declination relative to the horizon, the time of sunrise and sunset and duration of the day or night. During midnight sun sun's declination relative to the horizon is 20.535 degrees, the sun does not set, and the duration of the day is 24 hours (Picture 2).

Солнечный калькулятор

позволяет посчитать время восхода и захода Солнца на любой день года в любой точке Земли

Выберите город

Хатанга, Красноярский край, Россия

ПАРАМЕТРЫ

ДАТА:

Дек. 22 2016

ШИРОТА

>0 для Северной,
<0 для Южной

71.983

градусов

Временная зона:

+7 или

0

ДОЛГОТА

>0 для Восточной,
<0 для Западной

102.467

градусов

При выборе города из списка временная зона ставится для следующей за текущей даты. Для других дат Вам нужно выбрать её самостоятельно.

Посчитать

РАССЧИТАННЫЕ ЗНАЧЕНИЯ

Склонение Солнца: -23.427 градусов

Восход: --:--

Заход: --:--

Долгота дня: 00ч. 00м.

Picture 3 – Duration of the night during polar night [5]

During polar night sun's declination relative to the horizon is minus 23.427 degrees, the sun does not rise, and the duration of the day is 0 hours (Picture 3).

Therefore, it is possible to generate electricity using alternative energy sources - photoelectric power stations during the midnight sun. Electricity generation will be carried out within 24 hours for almost 3 months. But also electricity will not be produced within 2 months during the polar nights. Therefore, it is necessary to provide an additional electricity source, as well as accumulator batteries for the days of midnight sun.

In addition, it is necessary to take into account the cloudiness of this area, because even in the presence of a midnight sun, electricity generation may not be the maximum (Table 1).

The actual statistics data of cloudiness are taken from the RP5 site [6].

Table 1 - The actual statistics data of cloudiness [6]

| Month | Cloudiness in % |
|-----------|-----------------|
| January | 40 |
| February | 50 |
| March | 40 |
| April | 40 |
| May | 50 |
| June | 50 |
| July | 50 |
| August | 50 |
| September | 60 |
| October | 60 |
| November | 50 |
| December | 40 |

It can be seen from the Table 1, that in general the cloudiness is 50%.

Consequently, only further calculations will help us to estimate the solar potential for a given cloudiness.

1.3 Diesel power plant characteristics

Three diesel generators (one is in reserve) are installed at the diesel power plant near the Khatanga village. Their type is ED 50-T400-3RN with a capacity of 50 kW each, and they are made in block-container version with 3 degrees of automation: automatic start-up of the diesel generator, network backup, automatic refueling of fuel and oil (Table 2). Unattended operation of the DPP is provided for more than 24 hours (Figure 4) [7].



Picture 4 – Diesel – generator [7]

The diesel power plant with technological equipment is located inside of the insulated block - container (starting and working of the diesel power plant up to -50°C). There are automatic load transfer - ALT, the common bus-bar, additional fuel tanks, refueling system, oil, fire extinguishing system, alarm and system remote monitoring inside of the insulated block - container [7].

Table 2 - Characteristics of diesel power plant [7]

| Type of generator | P_{nom} kW | Fuel consumption (75% of load), L/h | Fuel tank, L | Generated current | f, Hz | Cost (RUB) |
|-------------------|-----------------|--|-----------------|--------------------|----------|------------|
| ED 50-T400-3RN | 50 | 11,6 | 200 | AC 3-phase current | 50 | 630 000 |

According to the manufacturer's recommendations, the permissible overload of these types of generators is no more than 10% of the rated power for no more than 1 hour for every 8 hours of operation, no more than 200 hours per year, and the recommended load should be in the range of 75%

to 90% of the rated power. Work with a load of less than 25% is not allowed for more than 5 minutes [7].

1.4 Consumer load graphs

Popigay's installed energy production capacity is 100 kW, so, I can calculate the reactive power (Equation 1), and can get typical daily load graphs for each season during the year.

$$Q = P_{\max} \cdot \operatorname{tg}(\varphi) = 100 \cdot 0,3286 = 32,86, \text{ kVar}, \quad (1)$$

Where $\operatorname{tg}(\varphi)$ – approximate power factor.

Approximate power factor corresponds to power factor 0.95 according to Russian quality standards in power systems engineering [8].

Table 3 - Popigay's installed energy production capacity

| Active Power $P_{\max}, \text{ kW}$ | Reactive Power $Q_{\max}, \text{ kVar}$ |
|--|--|
| 100 | 32,86 |

According to statistic data from the book Budzko I.A. "Electric power supply of villages" [8], I know typical load graphs in percent, but I can easily rebuild them in named units using Popigay's installed energy production capacity (Table 3).

So, the active power, consumed every hour during the day, is calculated by the equation 2:

$$P_h = k \cdot P_c, \quad (2)$$

Where P_h - power, consumed every hour during the day, kW,

P_c - calculated power, kW,

k - loading factor, %, [9, Table 3.3].

Consequently, the active power consumed in the winter from 00.00 to 01.00:

$$P_h = 0,25 \cdot 100 = 25 \text{ kW}.$$

The values of active power hourly consumption in winter, spring, summer and autumn are given in Table 4. In addition, further it will be taken into account that the maximum active capacity for the summer period is 30% less than for winter, and in spring and autumn are less from 10 to 20% [9].

Table 4 - Active power hourly consumption in each season of the year

| Hour | $P, \text{ kW}$ | | | |
|------|-----------------|--------|--------|--------|
| | Winter | Spring | Summer | Autumn |
| 1 | 25 | 20 | 14 | 23 |
| 2 | 25 | 20 | 14 | 23 |

Continue of table 4

| | | | | |
|----|-----|----|----|----|
| 3 | 25 | 20 | 14 | 23 |
| 4 | 25 | 20 | 14 | 23 |
| 5 | 25 | 20 | 18 | 23 |
| 6 | 35 | 28 | 21 | 32 |
| 7 | 50 | 36 | 28 | 41 |
| 8 | 60 | 40 | 32 | 50 |
| 9 | 40 | 32 | 28 | 36 |
| 10 | 30 | 24 | 21 | 27 |
| 11 | 30 | 24 | 21 | 27 |
| 12 | 35 | 28 | 21 | 32 |
| 13 | 40 | 32 | 25 | 36 |
| 14 | 30 | 24 | 21 | 27 |
| 15 | 30 | 24 | 21 | 27 |
| 16 | 30 | 24 | 21 | 27 |
| 17 | 40 | 24 | 21 | 27 |
| 18 | 70 | 32 | 21 | 36 |
| 19 | 100 | 40 | 25 | 63 |
| 20 | 95 | 56 | 28 | 90 |
| 21 | 70 | 80 | 49 | 77 |
| 22 | 50 | 16 | 70 | 54 |
| 23 | 35 | 40 | 42 | 36 |
| 24 | 35 | 24 | 18 | 27 |

Based on the calculations performed, we can construct daily load graphs for each season during the year for investigated object (Appendix A – Consumer load graphs).

To construct the annual active power graph, it is necessary to calculate the amount of power consumed monthly first, taking into account the seasonal coefficient [9, Table. 3.4].

Active power consumed in December:

$$W_{dec} = W_d \cdot k_s \cdot 31 = 1030 \cdot 1 \cdot 31 = 31930 \text{ kWh.} \quad (3)$$

Where W_d – daily consumption in calculated month, kWh,

k_s - seasonal coefficient.

Calculation is the same for the other months. The calculated data are presented in Table 5.


Table 5 – Total month active power load

| Month | k_s | W , kWh |
|----------|-------|-----------|
| January | 1 | 31 930 |
| February | 1 | 28 840 |
| March | 0,8 | 22 568 |
| April | 0,7 | 19 110 |

Continue of table 5

| | | |
|-----------|-----|--------|
| May | 0,7 | 19 747 |
| June | 0,7 | 18 165 |
| July | 0,9 | 24 134 |
| August | 0,9 | 24 134 |
| September | 0,9 | 26 460 |
| October | 1 | 30 380 |
| November | 1 | 29 400 |
| December | 1 | 31 930 |

The annual load graph is on the picture 5, constructed on the calculated data.



Picture 5 - The annual load graph

In summary, it can be concluded that typical energy consumption graphs of small village in the territory behind the polar circle were obtained as a result of the made calculations. The annual electricity consumption of the village is 306797 kWh per year.

The final project goal is the choice of the optimal variant of power supply for the investigated object and an assessment of the effectiveness of solar sources in the hybrid power plant.

Chapter 2

Potential assessment of renewable solar energy for investigated region

Solar energy is the main source of energy coming from space to the Earth's surface. The sun is a natural constantly operating thermonuclear reactor.

The statistical data for the investigated region of solar potential are taken from the USSR Climate Data book [10].

There are 162 days without sun during the year, from mid-October to mid-February [4].

The total month solar radiation on the horizontal surface is shown in Table 6.

Table 6 – Total month solar radiation [10]

| Month | Total solar radiation during the clear weather Q_c , kWh/m ² | Total solar radiation during an average cloudiness $Q_{c,}$ kWh /m ² |
|-----------|---|---|
| January | - | - |
| February | - | - |
| March | 52 | 21 |
| April | 111 | 86 |
| May | 170 | 159 |
| June | 242 | 153 |
| July | 260 | 154 |
| August | 243 | 99 |
| September | 183 | 43 |
| October | 98 | 18 |
| November | 40 | 3 |
| December | - | - |

It is known that there is an average cloudiness not below 40% during each month (Table 1). Thus, it is necessary to take into account in calculations the total solar radiation under average cloud conditions.

But further it is necessary to determine the optimal angle of solar panel inclination to make solar radiation is maximal. It is logical that the solar radiation will be maximal, when sunlight falls on the panel at a square corner of incidence.

2.1 The classical theoretical calculation of solar radiation

Three components of the radiation balance are taken into account, when I calculate solar radiation entering an inclined plane [11]:

$$Q_{incl} = S_{incl} + D_{incl} + R_{incl}, \quad (4)$$

Where,

Q_{incl} - total solar radiation falling on an inclined surface, W/m^2 ;

S_{incl} - direct solar radiation falling on an inclined surface, W/m^2 ;

R_{incl} – solar radiation reflected from the Earth's surface, W/m^2 .

Reflected solar radiation is negligible in the warm season, because of lack of snow cover, so, it can be neglected [11].

Approximate estimation of declination value of the Sun according to Cooper's formula (28th of March) [12]:

$$\delta = 0,41 \cdot \sin\left(2 \cdot \pi \cdot \frac{284+N}{365}\right), \quad (5)$$

Where,

N - the ordinal number of the day in the year, counted from the first January.

So,
$$\delta = 0,41 \cdot \sin\left(2 \cdot \pi \cdot \frac{284+87}{365}\right) = 0,042.$$

Next, determine the height of the sun and the angle of received solar radiation flux on the panel at various angles of inclination of the plane to the horizon according to the equation 6 [10]:

$$\begin{aligned} \cos\theta = & \sin\delta \cdot \sin\varphi \cdot \cos s - \sin\delta \cdot \cos\varphi \cdot \sin s \cdot \cos\gamma + \\ & \cos\delta \cdot \cos\varphi \cdot \cos s \cdot \cos\omega + \cos\delta \cdot \sin\varphi \cdot \sin s \cdot \cos\gamma \cdot \cos\omega \\ & + \cos\delta \cdot \sin s \cdot \sin\gamma \cdot \sin\omega \end{aligned} \quad (6)$$

Where,

φ – Latitude of the investigated object, rad,


δ – Inclination of the Sun, rad,

s – Angle of inclination of the plane to the horizon, rad.

The next step is researching the total solar radiation flux incidences on an inclined plane at various angles of inclination of the solar panel to the horizon in clear weather:

$$Q_{incl}(\varphi, \omega, \gamma, s, N) = S_{incl}(\varphi, \omega, \gamma, s, N) + D_{incl}(\varphi, \omega, s, N) \quad (7)$$

The graphical solution is represented on the Picture 6.



Picture 6 - The graph of total solar radiation on a plane inclined at different angles on a spring clear day

As it can be seen from Picture 6, the maximum amount of solar radiation falls on the plane inclined to the horizon at $5\pi/12$ angle.

After that I can determine the total radiation per day as an area under the solar insolation curve for the $5\pi/12$ angle.

$$\int_{-2}^2 Q_{incl}\left(w, \frac{5\pi}{12}\right) dw = 1344 \frac{\text{W}}{\text{m}^2} \cdot \text{rad}, \text{ so,} \quad (8)$$

$$1344 \cdot \frac{12}{\pi} = 5.134 \frac{\text{kW}}{\text{m}^2}.$$

The next step is researching the total solar radiation flux incidences on an inclined plane at various angles of inclination of the solar panel to the horizon in the cloudiness weather [11]:

$$Q_{cloud}(\varphi, \omega, \gamma, s, N) = (S_{incl}(\varphi, \omega, \gamma, s, N) + D_{incl}(\varphi, \omega, s, N)) \cdot (1 - (a + bn)n) \quad (9)$$


Where,

n - The number of clouds in unit fractions ($n = 0$ for a cloudless sky, $n = 1$ with an absolute cloudiness). Cloudiness is 40% in average in March.

b - Constant coefficient, which is equal 0.38,


a - Coefficient, which depends on the environment (land or sea) and on latitude.

The graphical solution is represented on the Picture 8.



Picture 8 - The graph of total solar radiation at the inclined angle 75deg on a spring cloudiness day

The same algorithm of calculations is for summer day, when midnight sun is observed. The 18th of June is taken as a control day. The data obtained are presented below (Picture 9).



Picture 9 - The graph of total solar radiation on a plane inclined at different angles on a summer clear day


As it can be seen on Picture 9, the maximum amount of solar radiation falls on the plane inclined at an angle of $\pi / 6$ to the horizon.

So, the total radiation per day is an area under the solar insolation curve for the $\pi/6$ angle:

$$\int_{-3.14}^{3.14} Q_{incl}\left(w, \frac{\pi}{6}\right) dw = 2058 \frac{\text{W}}{\text{m}^2} \cdot \text{rad}, \text{ so,} \quad (10)$$

$$2058 \cdot \frac{12}{\pi} = 7.861 \frac{\text{kW}}{\text{m}^2}.$$

Similarly is for a cloudiness day (Picture 10).



Picture 10 - The graph of total solar radiation at the inclined angle 30deg on a summer cloudiness day


Firstly we use the statistics data from the USSR Climate Data book (Table 6), since those values are more accurate and take into account the presence of twilight during the midnight sun. The presence of twilight can also be taken into account by calculations, but only approximately. And to maximize the value of solar radiation, it is necessary to ensure the right angle of the solar panels relative to the angle of incidence of the sun's flux. It is not possible to provide this in all months, so we will take 30% losses for refraction of the sun's rays [13]. And I also take into account the greater production of solar radiation during the day in comparison with the data taken from the USSR Climate Data book (Table 5), multiplying by a factor of 1.5. Because the measurements from this book were carried out, when the instruments were placed directly on a horizontal surface land without any angle.

So, we have new table 7 based on data from the table 6.


Table 7 – Total month solar radiation

| Month | Total solar radiation during an average cloudiness Q_c , kWh /m ² |
|-----------|--|
| January | - |
| February | - |
| March | 56 |
| April | 120 |
| May | 184 |
| June | 166 |
| July | 167 |
| August | 107 |
| September | 47 |
| October | 20 |
| November | 3 |
| December | - |

The solar activity of the investigated area and the electricity demand are shown in Pictures 11 and 12.



Picture 11 - The solar activity of the investigated area



Picture 12 – Electricity demand

Analyzing above graphs, I can make the following conclusions:

- 1) The most favorable months for the solar modules using are May, June and July, as midnight sun is observed during these months;
- 2) The minimum amount of total solar radiation and the maximum demand of electricity are observed from October to March. Village electricity supply is carried out with the diesel-generator;
- 3) Different volumes of fuel resources may be needed, depending on the total solar radiation in different months. It will save money in a result.


I will take into account all these features, when design photovoltaic power plant, and I will consider possibility to cover electricity demand fully in May and June, using solar energy.

2.2 Structural diagram of the power supply system

A hybrid power supply system should have at least two independent electricity sources in its structure [13]. In my case, this is the solar potential power plant and diesel fuel. Photovoltaic panels (PVP) will be used as the main energy source, and diesel generator (DG) is as a reserve source (Picture 13).

DG's power is turned on when the accumulated power is not enough to cover the load, or during the polar nights. It is necessary to charge the accumulator batteries during forced generator operation to provide working with the maximum efficiency.

The power supply system can be implemented using a single-phase or three-phase system. Typically, photoelectric mounting generates DC power at one voltage and charges the batteries through a charge controller. During maximum load periods, when the depth of accumulators discharge reaches the limit value, the DG must automatically start up and provide uninterrupted power supply of the electric receivers. There is an inverter in the system to convert DC to AC [13].



Picture 13 - Hybrid power supply system

On the Picture 13, DG with ATS is a diesel generator with automatic transfer switch, SP is solar panel, SC is solar controller, ACB is accumulator battery, I is inverter and L is load.

The designing of power supply schemes is proposed to be divided into two parts: power supply from renewable energy sources and power supply from diesel generators.

Chapter 3

Design of photovoltaic power station for the village behind the polar circle

3.1 Choice of solar modules

The choice of solar modules is based on the world practice of production and operation of solar cells. The most effective type is monocrystalline solar module. This type has efficiency from 14 to 16 percent. And it has good correspondence between quality, energy output and price [13]. That is why I have chosen monocrystalline solar modules HSE300-72M (Picture 14) made by Helios SolarWorks [14].



Picture 14 - Solar module HSE300-72M [14]

Technical characteristics are represented in the table 8.

Table 8 – Characteristics of solar modules [14]

| | |
|---------------------------------------|---------------------------------|
| Max power | 300 W |
| Rated voltage | 24 V |
| No-load voltage | 44,6 V |
| Short-circuit current | 8,74 A |
| Current at the point of maximum power | 8,21 A |
| Operating temperature | -40...+85 °C |
| Dimension | 1950 x 990 x 45 mm ² |
| Weight | 24 kg |
| Structure | Single-crystal |
| Number of cells | 72 (6x12) cells |
| Maximum system voltage | 1000 V DC |
| Cost, RUB | 22 680 |

However, I should take into account the gap between the elements, therefore I subtract 3% from the total area of the module and get the working area for further calculations [15].

$$S_{m1} = 1,95 \cdot 0,99 = 1,9305 \text{ m}^2,$$

$$S_{mw} = S_{m1} \cdot 0,97 = 1,873 \text{ m}^2.$$

It is needed to provide proper panels' orientation to the sun to increase the efficiency of solar panels. The optimal panels angle for summer and winter seasons were determined earlier.

Next, I will find the necessary number of solar modules to cover the demand for electricity in May, because the solar insolation in this month is the maximum. So, I take the meaning of demand for electricity in May and find necessary area of solar modules. The demand in May is 19 747 kWh.

$$S_{necess} = \frac{W_{necess}}{\eta \cdot Q_s} \quad (11)$$

Where Q_s – total solar radiation, kWh/m²,

η - efficiency of the solar module.

$$S_{necess} = \frac{19747}{183,34 \cdot 0,14} = 770 \text{ m}^2$$

Knowing the required area and area of one module, I can find the required number and cost of modules (Equation 13):

$$N = \frac{S_{necess}}{S_{mod}} \quad (12)$$

Where,

S_{mod} - the area of one module, m².

$$N = \frac{770}{1,873} = 412$$

I take 432 solar modules in order to be able to connect them in series and parallel. So, there are 9 parallel branches of 8 solar panels in each, connected in series. And there are 6 separate photovoltaic blocks located territorially in one locality.

Depending on the amount of total monthly radiation, these modules will produce a different amount of electricity. Using equation 11, I will find the amount of electricity generated by the modules in each month (Table 9).

Table 9 - Electricity generated by solar modules

| | March | April | May | June | July | Aug. | Sent. | Oct. |
|----------------|-------|--------|--------|--------|--------|--------|-------|-------|
| W_{mod} (kW) | 6 421 | 13 840 | 21 176 | 19 125 | 19 263 | 12 308 | 5 355 | 2 226 |

Continue of table 9

| | |
|---|-----------|
| Area of modules - S_{mod} (m ²) | 809 |
| Number of modules – N | 432 |
| Cost (RUB) | 9 797 760 |

Thus, in May and June, sufficient electricity will be generated to cover completely the demands of electricity. In other months, there is a shortage of electricity, so, it is necessary to use diesel generators as additional power supplies.

Table 10 - Electricity balance using solar modules

| Month | Solar radiation Q_c (kWh/m ²) | Demand of electricity- W_{necess} (kWh) | Electricity from solar modules - W_{mod} (kWh) | Deficit of electricity – W_a (kWh) |
|-----------|---|---|--|--------------------------------------|
| March | 56 | 22 568 | 6421 | -16 147 |
| April | 120 | 19 110 | 13 840 | -5 271 |
| May | 184 | 19 747 | 21 176 | 1 429 |
| June | 166 | 18 165 | 19 125 | 960 |
| July | 167 | 24 134 | 19 263 | -4 871 |
| August | 107 | 24 134 | 12 309 | -11 826 |
| September | 47 | 26 460 | - | -26 460 |
| October | 20 | 30 380 | - | -30 380 |

The solar panels are chosen for the summer season, when the solar activity is maximal at the minimum load, and the diesel-generator is chosen for the winter season, when the solar activity is minimal, and the load is maximal during the day. Some part of solar radiation will be used to reduce the consumption of diesel fuel in spring. In autumn, the power produced by the panels is not sufficient even to cover the load power, in this case only the diesel generator will work, because the photoelectric power plant operates separately with the diesel generator. But ACB will work during the whole year to maintain the battery charge during the winter and autumn periods in order to extend their service life [13]. But in autumn and winter seasons the load will be fully provided with a diesel generator.

3.2 Choice of accumulator batteries

The efficiency and reliability of the photovoltaic plant is increasing with using of accumulator batteries, because it will allow reserving of excess power produced by solar panels and using it in the future when solar activity is not so high.

I choose the DELTA DTM12200L battery [16]. It is also necessary to take into account the fact that to prolong operation life; the battery should always retain at least 40% of the charge [16].

Even in the presence of a midnight sun, there is twilight during the day, when solar activity is not so high. In this case, equipment operation will be considered for a typical days in May and June, when there is sufficient generation capacity to cover the required load. Daily characteristic loads are shown in Appendix B, Picture B.1-B.2.

It is also known hourly solar radiation from the USSR Climate Data book [10] for different months, but with assumption that according to proper corner of solar panels, insolation is increasing in 1.5 times, but 30% of losses is also present. The data are summarized in Table 11.

Table 11 - Hourly total solar radiation during an average cloudiness and power generation of solar panels

| Time, hour | Solar insolation, kW/m ² | | Power generation of solar panels (420 pc), kW | |
|------------|-------------------------------------|------|---|------|
| | May | June | May | June |
| 0-1 | 0,00 | 0,01 | 0,00 | 1,2 |
| 1-2 | 0,01 | 0,02 | 1,2 | 2,3 |
| 2-3 | 0,01 | 0,04 | 1,2 | 4,6 |
| 3-4 | 0,04 | 0,08 | 4,6 | 9,2 |
| 4-5 | 0,09 | 0,12 | 10,4 | 13,9 |
| 5-6 | 0,16 | 0,19 | 18,5 | 22,0 |
| 6-7 | 0,24 | 0,22 | 27,7 | 25,4 |
| 7-8 | 0,32 | 0,28 | 37,0 | 32,3 |
| 8-9 | 0,39 | 0,34 | 45,0 | 39,3 |
| 9-10 | 0,46 | 0,40 | 53,1 | 46,2 |
| 10-11 | 0,51 | 0,45 | 58,9 | 52,0 |
| 11-12 | 0,55 | 0,47 | 63,5 | 54,3 |
| 12-13 | 0,55 | 0,47 | 63,5 | 54,3 |
| 13-14 | 0,52 | 0,45 | 60,1 | 52,0 |
| 14-15 | 0,47 | 0,41 | 54,3 | 47,4 |
| 15-16 | 0,41 | 0,35 | 47,4 | 40,4 |
| 16-17 | 0,34 | 0,31 | 39,3 | 35,8 |
| 17-18 | 0,26 | 0,25 | 30,0 | 28,9 |
| 18-19 | 0,17 | 0,19 | 19,6 | 21,9 |
| 19-20 | 0,11 | 0,13 | 12,7 | 15,0 |
| 20-21 | 0,07 | 0,08 | 8,1 | 9,2 |
| 21-22 | 0,03 | 0,04 | 3,5 | 4,6 |
| 22-23 | 0,01 | 0,02 | 1,2 | 2,3 |
| 23-24 | 0,00 | 0,01 | 0,0 | 1,2 |

Data of hourly loads for typical days in May and June are presented in Table 12. And also the difference between the produced power and load power is there.

Table 12 – Hourly load data and produced power

| Time, hour | Load, kW | | Difference between produced and required capacities, kW | |
|------------|----------|------|---|------|
| | May | June | May | June |
| 0-1 | 18 | 14 | -18 | -13 |
| 1-2 | 18 | 14 | -17 | -12 |
| 2-3 | 18 | 14 | -17 | -10 |
| 3-4 | 18 | 14 | -13 | -5 |
| 4-5 | 18 | 18 | -7 | -4 |
| 5-6 | 25 | 21 | -6 | 1 |
| 6-7 | 32 | 28 | -4 | -3 |
| 7-8 | 35 | 32 | 2 | 1 |
| 8-9 | 28 | 28 | 17 | 12 |
| 9-10 | 21 | 21 | 32 | 25 |
| 10-11 | 21 | 21 | 38 | 31 |
| 11-12 | 25 | 21 | 39 | 33 |
| 12-13 | 28 | 25 | 36 | 30 |
| 13-14 | 21 | 21 | 39 | 31 |
| 14-15 | 21 | 21 | 34 | 27 |
| 15-16 | 21 | 21 | 27 | 20 |
| 16-17 | 21 | 21 | 19 | 15 |
| 17-18 | 28 | 21 | 2 | 8 |
| 18-19 | 35 | 25 | -16 | -3 |
| 19-20 | 49 | 28 | -37 | -13 |
| 20-21 | 70 | 49 | -62 | -40 |
| 21-22 | 14 | 70 | -11 | -66 |
| 22-23 | 35 | 42 | -34 | -40 |
| 23-24 | 21 | 18 | -21 | -17 |

Graphs of load capacity and solar insolation are presented in Appendix B, Picture B.3-B.4.

As it can be seen from Pictures B.3-B.4 in Appendix B, the solar insolation is maximal from 7 a.m. to 6 p.m., and the required load is completely covered. Moreover excessive energy is generated, which should be accumulated in batteries and used in those hours when it is necessary. The maximum excessive energy that should be stored is observed from 7 a.m. to 6 p.m., and it is 282.62 kWh. Daily graphs of load power and solar insolation for the other months are presented in Appendix B, Pictures B.5-B.10.

Technical characteristics of chosen battery are presented in Table 13.

Table 13 - Technical characteristics of accumulator battery [16]

| | |
|---------------------------------|---|
| Voltage | 12 V |
| Capacity | 200 Ah |
| Level of operating temperatures | Discharge: from -20 °C to +60 °C Charge: from -10 °C to +50 °C Storage: from -20 °C to +60 °C |
| Active material | Lead |
| Max charging rate | 60 A |
| Battery fluid | High purity sulfuric acid |
| Dimension | 522 x 238 x 223 mm |
| Weight | 65,6 kg |
| Cost | 23 520 RUB |

Battery capacity is calculated according to the equation 13, taking into account the losses and the permissible depth of discharge [13]:

$$W_{ACB} = \frac{U \cdot C_I \cdot k_d \cdot d_{ACB}}{1000}, \quad (13)$$

Where,

U – rate voltage, V;

C_I – rate capacity, Ah;

k_d - the battery discharge factor (discharge recommendation is up to 40%) [13].

So,

$$W_{ACB} = \frac{12 \cdot 200 \cdot 0,4}{1000} = 0,96 \text{ kWh}$$

The following number of batteries will be required in case of the charge-discharge losses (Equation 14) [13]:

$$n = \frac{W_{exc}}{W_{ACB} \cdot 1.1}, \quad (14)$$

So,

$$n = \frac{282.62}{0.96 \cdot 1.1} \approx 268 \text{ units}$$

Thus, I take for installation the 288 battery units. Twelve branches in parallel with 4 batteries each, connected in series. And there are 6 separate photovoltaic blocks located territorially in one locality.

3.3 Choice of solar controllers

The chosen type of accumulator batteries is recommended to be equipped with universal charge-discharge controllers Prosolar SunStar MPPT SS 24^{0C}X (Picture 15) [17].



Picture 15 - MPPT Battery charge controller for solar modules [17]

Such controllers provide the following options:

- Combines the built-in function MPPT (Maximum Power Point Tracking - monitoring the maximum power point of the solar battery), control the battery charge, display representation of information about the state of battery charge.
- Provide the maximum output power without reducing it at ambient temperatures up to 50°C.
- Can be used with lead-acid, gel and AGM-batteries, performs 2/3/4-stage charge with the ability to adjust all parameters and charging mode.
- Optimal connection of the photovoltaic module circuit is up to 192 V of DC (maximal voltage is 240 V).
- Ability to combine up to 16 controllers in one system to provide higher charge currents.
- Accurate charging of 12V/24V/36V/48V batteries.
- Built-in temperature compensation functions for safe and full charging of batteries.
- Can charge lead-acid batteries: with liquid electrolyte, gel, AGM and also lithium LiFePO4 batteries [17].

I take 6 controllers for the installation.

3.4 Choice of inverters

The choice of inverters is based on the following important characteristics:

1. Input voltage.

In my case the output controller's voltage is 48 V, and output power is more than 1500 W, it is recommended to use this voltage in order to reduce losses [18], so, I choose an inverter with an input voltage 48 V.

2. Rate and peak output power.

Inverter's rate output power must be equal to the sum power of all loads. However, rate power is determined as the maximum load power to simplify calculation. So,

$$P_{\max.calc} = P_{calc} = 100, \text{ kW.}$$

3. Shape of the output voltage.

The form of the output voltage must be pure sinewave in order to provide receivers with high-quality electric power.


Since the maximum load power is 100 kW, I take 6 Dominator power inverters of 20 kW each by MicroArt [19]. Technical characteristics of the taken inverters are presented in Table 14.

Table 14 – Technical characteristics of the inverters [19]

| | |
|---------------------------|--------------------|
| Rate power | 20 kW |
| Input voltage | 48 V |
| Output voltage | 220 V |
| Frequency | 50 Hz |
| Output signal | Pure sinewave |
| Efficiency rate | 92-96 |
| Min / Max capacity of ACB | 800/2400 Ah |
| Dimension | 550 x 217 x 153 mm |
| Cost | 222 700, RUB |

Also the MAP Dominator inverter has such an important advantage as: the ability to synchronize not only with the 220V network (or with an electric generator), but also in parallel between other MAP Dominator inverters (up to 10 pcs in parallel) [19].

3.5 Schematic diagram of the Photovoltaic Power Plant



Picture 16 - Schematic diagram of the photovoltaic power plant

Chapter 4

Financial model

4.1 Theoretical background

There are some most important investment criteria in financial model. It is [20]:

- Net Present Value (NPV);
- Internal Rate of Return (IRR);
- Profitability Index (PI);
- Payback Period (PP).

I will write more detailed about each criterion further.

4.1.1 Net Present Value

The difference between a project's value and its cost is Net Present Value (NPV) [21].

NPV is used in capital budgeting to analyze the profitability of a projected investment or project.

The following is the formula for calculating NPV [22]:

$$NPV = \sum_{t=1}^T \frac{C_t}{(1+r)^t} - C_0, \quad (15)$$

Where

C_t - net cash inflow during the period t ;

C_0 - total initial investment costs;

r - discount rate;

t - number of time periods.

Net Present Value Rule says that investments should be made only for positive NPV values [22].

4.1.2 Internal Rate of Return

The discount rate that makes NPV 0 is the rate of return [21].

$$NPV = -C_0 + \sum_{i=1}^T \frac{CF_i}{(1+IRR)^i} = 0 \quad (16)$$

Where

CF_i - cash flows (both inflow and outflow);

C_0 - total initial investment costs;

NPV – net present value;

T - number of time periods.

And the rule of IRR says: “Accept investment opportunities offering rates of return in excess of their opportunity costs of capital.” [21]

4.1.3 Profitability Index (PI)

Profitability index is the value which illustrates the ratio of project’s future cash flows in the present value over investments. The formula is showed below [21]:

$$PI = \frac{\sum_{i=1}^T DCF_i (1+r)^i}{INV}, \quad (17)$$

Where

DCF – discounted cash flow;

r – discount rate;

INV – investments;

T – lifetime period.

“The rule of profitability index” claims: if a project has profitability index higher than one, it should be accepted, otherwise – the better way is to avoid it [23].

4.1.4 Payback period

A project’s payback period is found by counting the number of years it takes before the cumulative cash flow equals the initial investment.

The payback rule states that a project should be accepted if its payback period is less than some specified cutoff period. Moreover, the payback rule ignores all cash flows after the cutoff date [21].

As it was mentioned before, simple payback period is the period of time which is needed to return the investments. The simple description is represented below:

$$(C_i - C_0)_1 + (C_i - C_0)_2 + \dots + (C_i - C_0)_T = \sum_{i=1}^T (C_i - C_0)_t \geq C_0 \quad (18)$$

Where

Co – cash outflow;

Ci – cash inflow.

4.2 Economic parameters

4.2.1 Inflation

Inflation is a sustained increase in the general price level of goods and services in an economy over a period of time [24], but government controls increasing of prices in some fields. So, according to Scenario conditions of socio-economic development of the Russian Federation the inflation rate is 4% [25].

4.2.2 Tax shield

It is government project, so, no any taxes in this case.

4.2.4 Depreciation

There are two main methods of depreciation in financial management:

1. Straight-Line Method;
2. Accelerated Method.

The Straight Line Method is the simplest method. This amortization method based on the basic equation:

$$D = \frac{INV}{T}, \quad (19)$$

Where

INV – investments of each item,

T – item's lifetime.

Accelerated methods used in accounting for higher values of depreciation in the beginning of the lifetime period [26]. So, these methods had good impact on cash flow if the project would have a few amount of money in the earlier years.

In my project Straight-Line Method will be used. But the different lifetime is for the different equipment, so, the depreciation will be also changed.

4.2.4 Discount rate

Discount rate is the interest rate that is used to re-evaluate the value of future capital at the current time [27].

It is government project, so, according to Decree of the Russian Federation Government №1470 [28], the next value of the discount rate for the investment money into the new technology is there. It is 18-20%, I take 18%.

4.3 Financial model

To calculate financial model I need as technical data as data of economic parameters. I have described found economic parameters above. As for technical parameters and costs of equipment, the data from previous chapters are presented in the table 15.

Table 15 – Collected Data for the financial model

| Item | Units of each item |
|------------------------------------|--------------------|
| Installed Power, kW | 129,6 |
| Investment per 1 kW, RUB | 392 126 |
| Tmax, hours | 692 |
| Tl of photovoltaic panels, years | 20 |
| Tl of accumulator batteries, years | 7 |
| Tl of controllers, years | 10 |
| Tl of inverters, years | 10 |
| Discount rate, % | 18 |
| Operation cost, RUB | 1% |
| Existing price, RUB | 100 |
| Escalation rate, % | 4 |

4.3.1 Net Present Value (NPV)

In my model I got negative NPV and its result is -42,8 million rubles with price for electricity 95 RUB (Appendix C, Table C.1).

4.3.2 Internal Rate of Return (IRR)

The value of IRR in my project is absent, because the project is absolutely not economic effective.

4.3.3 Profitability Index (PI)

The value of profitability Index is presented below:

$$PI = \frac{18303034}{47288732} = 0,39.$$

According to “the rule of profitability index” it is better to avoid this project, because PI is less, than one.

4.3.4 Payback Period (PP)

Payback Period is bigger than lifetime of the project that is why this project should not be accepted.

All calculation results of financial model are presented in the Appendix C. The minimum price for 1 kW is 579 RUB, when NPV is 0, but now the existing price is 100 RUB [13], that means absolutely not economic effective project. To estimate this project fully, it is necessary to do sensitivity analysis.

Chapter 5

Financial analysis

Most common financial analysis are:

- Sensitivity analysis;
- Scenario.

5.1 Sensitivity analysis


Financial analysis includes financial model and sensitivity analysis. Sensitivity analysis shows influence of changing of input parameters on NPV and helps to estimate which parameters have bigger influence [29].

In this chapter sensitivity analysis will be done for:

- Dependence NPV on discount rate;
- Dependence NPV on electricity price;
- Dependence NPV on useful life;
- Dependence NPV on escalation.

To estimate this project better, I assume that price for 1 kW is 95 RUB, not 579 RUB as I have calculated minimum price before to be more competitive with electricity price generated by diesel generators.


5.2 Dependence NPV on discount rate



Picture 17 - Dependence NPV on discount rate

NPV is decreasing with the increasing of discount rate. The picture 17 shows that the value of IRR – intersection of curve with the horizontal axe (the axe of discount rate) is absent. It means that there is no such value of discount rate, which could make the project economic effective.


5.3 Dependence NPV on electricity price



Picture 18 - Dependence NPV on electricity price

Picture 18 represents the linear dependence NPV on price; the price is higher, the NPV is bigger. It also shows that the minimum price for electricity is too high to cover all production costs. It even does not intersect the curve with a horizontal axe. The value of minimum price is approximately 579 RUB, but the market price is 100 RUB.

5.4 Dependence NPV on useful life of solar panels




Picture 19 - Dependence NPV on useful life of solar panels

The NPV value depends on lifetime period as well. According to picture 19, NPV value is rising with increasing of lifetime. So, if project's lifetime is bigger, the project is more profitable. But in my case the intersection of curve with a horizontal axe is absent, so, it means that with this price it is not

possible to cover all costs and investment. And moreover, it is needed to do additional investments at 8th year, 11th and 15th, because lifetime of equipment is different.

5.5 Dependence NPV on escalation



Picture 20 - Dependence NPV on escalation

With increasing of escalation, NPV will be increasing also, because the revenues is much bigger than cost of expenses, so, it has bigger influence on NPV. But still there is no such escalation, when NPV would be positive

Sensitivity analysis showed that this project is not economic effective absolutely, because the investment is much bigger than the profit from produced energy by photovoltaic panels. And lifetime of such equipment as accumulator batteries, inverters and controllers is less than the lifetime of solar panels that will require additional investments during the whole life time of the project. I will calculate economic effectiveness of this project on the example of saved fuel for the diesel generators in the next chapter.

Chapter 6


Comparative analysis of two power supply system operations

I will present a comparative analysis of two power supply system operations. The first variant includes photovoltaic panels, storage batteries and diesel generators. The second variant includes only diesel generators. Comparative analysis will be carried out according to the amount of fuel consumption.

The final cost of diesel fuel on the far North is 52.0 RUB / liter according to the prices of supplier [30].

6.1 Diesel generators power supply

I will define the total fuel consumption when only diesel generators operate. The fuel consumption at the nominal load is known from the passport data [7], but since the generator is loaded in each hour differently depending on the season, it is necessary to calculate the fuel consumption for a given load value. I know consumption of fuel from the passport data in three points: when the load is 50%, 75% and 100%. So, the curve of consumption and equation of this dependence are presented on the picture 21.



Picture 21 - Dependence of fuel consumption on load

From the picture 21 it is obtained that the minimum consumption (257 g/kWh) will be, when the load is 85%. So, according to this curve I can calculate fuel consumption for different loads in each month. Data of loads are taken from table 4. The table with calculated results of fuel consumption depending on load is presented in Appendix D.

The calculated monthly consumption of fuel and its prices are presented below.

Table 17 - The monthly consumption of fuel and its prices

| Month | Per day, l | Per month, l | Price, RUB | Total cost, RUB |
|---------|------------|--------------|------------|-----------------|
| January | 234 | 7254 | 52 | 377 208 |

Continue of table 17

| | | | | |
|----------------|-----|--------------|----|------------------|
| February | 234 | 6552 | 52 | 340 704 |
| March | 242 | 7502 | 52 | 390 104 |
| April | 242 | 7260 | 52 | 377 520 |
| May | 242 | 7502 | 52 | 390 104 |
| June | 213 | 6390 | 52 | 332 280 |
| July | 213 | 6603 | 52 | 343 356 |
| August | 213 | 6603 | 52 | 343 356 |
| September | 290 | 8700 | 52 | 452 400 |
| October | 290 | 8990 | 52 | 467 480 |
| November | 290 | 8990 | 52 | 467 480 |
| December | 234 | 7254 | 52 | 377 208 |
| Totally | - | 89600 | 52 | 4 659 200 |

The total cost of fuel per year is 4.659 million rubles.

6.2 Power supply from photovoltaic panels and diesel generators

In the second variant of power supply, the load will be covered by the photovoltaic panels partly. During the polar nights and autumn, the fuel consumption will be the same as in the first variant. Data of generated power by PV panels and the amount of operating hours are taken from Appendix B, Pictures B.5-B.10. The calculated data are presented in Table 18.

Table 18 - Data of the fuel and energy savings due to the PV panels operating

| Month | Demand per month, kWh | Per month, l | Price, RUB | Total cost, RUB |
|-----------|-----------------------|--------------|------------|-----------------|
| January | 31 930 | 7254 | 52 | 377 208 |
| February | 28 840 | 6552 | 52 | 340 704 |
| March | 16 147 | 6704 | 52 | 348 608 |
| April | 5 271 | 3216 | 52 | 167 232 |
| May | - | 0 | 52 | - |
| June | - | 0 | 52 | - |
| July | 4 871 | 2042 | 52 | 106 184 |
| August | 11 825 | 4670 | 52 | 242 840 |
| September | 21 105 | 8700 | 52 | 452 400 |
| October | 28 154 | 8990 | 52 | 467 480 |
| November | 29 400 | 8990 | 52 | 467 480 |
| December | 31 930 | 7254 | 52 | 377 208 |

Continue of table 18

| | | | | |
|----------------|---|--------------|----|------------------|
| Totally | - | 64372 | 52 | 3 347 344 |
|----------------|---|--------------|----|------------------|

So, the difference in total cost is 1.311 million rubles. Economy of fuel in liters is 25 228.

It means that the government could save only 1.311 mln rubles per year using PV power plant, but the whole investment for 20 years is 39.2 mln rubles. So, it takes about 30 years to cover all investments without any profit, but after 20 years it will be necessary to change equipment on new one that will require additional investment again. So, the project is not economic effective from the point of saving fuel costs also.

But it was realistic scenario when both of consumption and fuel cost are according to expected value. And to make financial analysis better it is recommended to do other scenarios also.

Chapter 7

Scenarios

Scenario analysis allows seeing, how project's outcomes change, if several assumptions will suddenly change. Therefore it shows how the project will going on if it happens [21].

However, scenario analysis has several drawbacks. Scenario analysis limited to outcomes. In other words, there is no strict description of realistic or pessimistic scenarios [31].

For this project three different scenarios are assumed. They are:

- 1) Realistic;
- 2) Pessimistic;
- 3) Optimistic scenario;

According to study presented by researchers, realistic scenario includes expected all inputs at the expected level, so called real values [31]. In this case, as a realistic scenario the option with expect cost of fuel and consumption of fuel are adopted.

Further, pessimistic scenario is. This option is estimated as a worse variant. In pessimistic scenario most inputs values are at the lower level, than expected [31]. In this variant cost of fuel is higher, than it is and consumption of fuel is also higher, than it is.

An optimistic scenario is determined as the best option [31]. In other words, it shows the highest possible savings of money. For the work it could be an option with expected cost of fuel (less, than it is) and consumption of fuel (also less, than it is).

7.1 Optimistic scenario


In this case I assume that because of economic situation on Russian market 1 RUB could be more stable and could have bigger value as currency. So, the price on fuel is assumed to be less on 20% than it is now. It is 42 RUB per liter. And electricity demand is also less on 20%, because of changes in population of this village.

But if load is less on 20%, it means that it will be also necessary to install new diesel generators with less installed capacity. Two new diesel generators are AD-35 (MMZ D-243) [32]. Characteristics of new diesel power plant are below.

Table 19 - Characteristics of new diesel power plant [32]

| Type of generator | P_{nom} kW | Fuel consumption (75% of load), L/h | Fuel tank, L | Generated current | f, Hz | Cost (RUB) |
|-------------------|-----------------|--|-----------------|--------------------|----------|------------|
| AD-35 (MMZ D-243) | 35 | 8.9 | 200 | AC 3-phase current | 50 | 495 000 |

22. And its curve of consumption and equation of this dependence are presented on the picture



Picture 22 - Dependence of fuel consumption on load

The calculated monthly consumption of fuel, when demand is covered only with diesel generators, is presented below. And prices of consumption are presented below also.

Table 20 - The monthly consumption of fuel and its prices

| Month | Per day, l | Per month, l | Price, RUB | Total cost, RUB |
|----------------|------------|---------------|------------|------------------|
| January | 272 | 8432 | 42 | 354 144 |
| February | 272 | 7616 | 42 | 319 872 |
| March | 230 | 7130 | 42 | 299 460 |
| April | 230 | 6900 | 42 | 289 800 |
| May | 230 | 7130 | 42 | 299 460 |
| June | 218 | 6540 | 42 | 274 680 |
| July | 218 | 6758 | 42 | 283 836 |
| August | 218 | 6758 | 42 | 283 836 |
| September | 262 | 7860 | 42 | 330 120 |
| October | 262 | 8122 | 42 | 341 124 |
| November | 262 | 7860 | 42 | 330 120 |
| December | 272 | 8432 | 42 | 354 144 |
| Totally | - | 89 538 | 42 | 3 760 596 |

The total cost of fuel per year is 3.760 million rubles.

In the second variant of power supply, the load will be covered by the photovoltaic panels partly.

Table 21 - Data of the fuel and energy savings due to the PV panels operating

| Month | Demand per month, kWh | Per month, l | Price, RUB | Total cost, RUB |
|----------------|-----------------------|---------------|------------|------------------|
| January | 25 544 | 8432 | 42 | 354 144 |
| February | 23 072 | 7616 | 42 | 319 872 |
| March | 12 918 | 6333 | 42 | 265 986 |
| April | 4 217 | 3612 | 42 | 151 704 |
| May | - | 0 | 42 | - |
| June | - | 0 | 42 | - |
| July | 44 | 3101 | 42 | 130 242 |
| August | 9 460 | 4602 | 42 | 193 284 |
| September | 16 884 | 7860 | 42 | 330 120 |
| October | 22 524 | 8122 | 42 | 341 124 |
| November | 23 520 | 7860 | 42 | 330 120 |
| December | 25 544 | 5841 | 42 | 245 322 |
| Totally | - | 63 379 | 42 | 2 661 918 |

So, the difference in total cost is 1.098 million rubles. Economy of fuel in liters is 26 159. It means if demand of electricity and price of fuel are less, than it is expected, government could save less money with using PV modules, but investments are still big. Therefore it is even more not economic effective, than it was in realistic scenario, in spite of covering almost all demand with PV in July also, not only in May and June. In this case it is more profitable to use diesel-generators.

7.2 Pessimistic scenario

In this case I assume that because of economic situation on Russian market 1 RUB could be less stable and could have less value as currency. So, the price on fuel is assumed to be higher on 20% than it is now. It is 63 RUB per liter. And electricity demand is also higher on 20%, because of changes in population of this village.

The calculated monthly consumption of fuel, when demand is covered only with diesel generators, is presented below. And prices of consumption are presented below also.

Table 22 - The monthly consumption of fuel and its prices

| Month | Per day, l | Per month, l | Price, RUB | Total cost, RUB |
|----------|------------|--------------|------------|-----------------|
| January | 392 | 12152 | 63 | 765 576 |
| February | 392 | 10976 | 63 | 691 488 |
| March | 290 | 8990 | 63 | 566 370 |
| April | 290 | 8700 | 63 | 548 100 |
| May | 290 | 8990 | 63 | 566 370 |

Continue of table 22

| | | | | |
|----------------|-----|----------------|----|------------------|
| June | 253 | 7590 | 63 | 478 170 |
| July | 253 | 7843 | 63 | 494 109 |
| August | 253 | 7843 | 63 | 494 109 |
| September | 338 | 10140 | 63 | 638 820 |
| October | 338 | 10478 | 63 | 660 114 |
| November | 338 | 10140 | 63 | 638 820 |
| December | 392 | 12152 | 63 | 765 576 |
| Totally | - | 115 994 | 63 | 7 307 622 |

The total cost of fuel per year is 7.308 million rubles.


In the second variant of power supply, the load will be covered by the photovoltaic panels partly.

Table 23 - Data of the fuel and energy savings due to the PV panels operating

| Month | Demand per month, kWh | Per month, l | Price, RUB | Total cost, RUB |
|----------------|-----------------------|---------------|------------|------------------|
| January | 38 316 | 12152 | 63 | 765 576 |
| February | 34 608 | 10976 | 63 | 691 488 |
| March | 20 661 | 8468 | 63 | 533 484 |
| April | 9 092 | 5549 | 63 | 349 587 |
| May | 2 520 | 2377 | 63 | 149 751 |
| June | 2 673 | 1669 | 63 | 105 147 |
| July | 9 698 | 4449 | 63 | 280 287 |
| August | 16 652 | 7480 | 63 | 471 240 |
| September | 25 326 | 10140 | 63 | 638 820 |
| October | 33 785 | 10478 | 63 | 660 114 |
| November | 35 280 | 10140 | 63 | 638 820 |
| December | 38 316 | 12152 | 63 | 765 576 |
| Totally | - | 96 030 | 63 | 6 049 890 |


So, the difference in total cost is 1.258 million rubles. Economy of fuel in liters is 19 964. But this amount of PV modules even could not cover demand of electricity even in May and June, as it was in realistic scenario.

New graphs of load capacity and solar insolation in May and June are presented below.



Picture 23 - Graphs of load capacity and solar insolation in May

In May it will be possible to cover demand by PV only from 9 a.m. to midnight.



Picture 23 - Graphs of load capacity and solar insolation in June

In June it will be possible to cover demand by PV from 9 a.m. to 2 a.m.

In this case it is more profitable to use diesel-generators.

Other variants of scenarios with combination optimistic price and realistic consumption, for example, are also calculated. Results are presented in the Table 24. Saving of fuel consumption and savings in RUB are at the intersection. Full calculations are in Appendix E.

Table 24 – All variants of scenarios

| Cost of fuel\ Fuel consumption | Optimistic (less than it is) | Realistic | Pessimistic (more than it is) |
|-----------------------------------|--|--|--|
| Optimistic, 42 RUB | 1,098 million rubles; 26 159 liters | 1,059 million rubles; 25 228 liters | 0.839 million rubles; 19 964 liters |
| Realistic, 52 RUB | 1,360 million rubles; 26 159 liters | 1,311 million rubles; 25 528 liters | 1,038 million rubles; 19 964 liters |
| Pessimistic, 63 RUB | 1,648 million rubles; 26 159 liters | 1,589 million rubles; 25 228 liters | 1,258 million rubles; 19 964 liters |

If demand of electricity is higher on 20%, as it is in pessimistic scenario, government could save less fuel of consumption, because PV modules could not cover demand absolutely even in May and June.

Conclusion

The initial aim of this Master's thesis was to design parallel photovoltaic power plant of village behind the polar circle and estimate economic feasibility of the project. The whole work was divided into seven main chapters with several subparts in each of them.

The first chapter was devoted to technical and climatic features of the investigated object. As for technical features, the category of village power supply reliability is third. Installed power capacity is 100 kW that have helped to build typical daily load graphs for each season during the year, taking into account statistic data [8]. The annual electricity consumption of the village is 306797 kWh per year. Moreover, three diesel generators (one is in reserve) are installed at the diesel power plant. As for climatic features, investigated village locates in the territory behind the polar circle. It means that the main climatic feature of this village is the presence of a midnight sun and a polar night. The polar night at the Khatanga latitude lasts from 17th of November to 25th of January, the midnight sun lasts from 9th of May to 4th of August. But potential assessment of renewable solar energy is presented in the second chapter.

In the second chapter calculation of solar radiation was made with two methods. The first method is connected with using statistical data from the USSR Climate Data book [9], which had being collected during fifty years. The second method is connected with using classical theoretical calculation of solar radiation [10]. So, I got total month solar radiation, combining these two methods. Analyzing obtained information, I made the following conclusion: the most favorable months for the solar modules using are May, June and July, as midnight sun is observed during these months. Structural diagram of the power supply system was also made in this chapter.

The third chapter was about designing of photovoltaic power plant for the village behind the polar circle. In this chapter choice of all necessary equipment was realized. So, photovoltaic power plant includes 432 solar modules, 288 accumulator battery units, 6 controllers and 6 power inverters. Schematic diagram of the photovoltaic power plant is also in this chapter.

The aim of the fourth chapter was economic analysis. Precisely, the main financial indicators: NPV, IRR, IP, PP. In my model I got negative NPV and its result was -42,8 million rubles with price for electricity 95 RUB. The value of IRR in my project was absent, because the project is absolutely not economic effective. As for PI, it is equal to 0.39. According to "the rule of profitability index" it is better to avoid this project, because PI is less, than one. Payback Period was bigger than lifetime of the project that is why this project should not be accepted. The minimum price for 1 kW is 579 RUB, when NPV is 0, but now the existing price is 100 RUB [12], that means absolutely not economic effective project.

But sensitivity analysis was made in the fifth chapter to estimate this project fully. Sensitivity analysis showed that this project is not economic effective absolutely, because the investment is much bigger than the profit from produced energy by photovoltaic panels. And lifetime of such equipment as accumulator batteries, inverters and controllers is less than the lifetime of solar panels that will require additional investments during the whole life time of the project.

In next sixth chapter I calculated economic effectiveness of this project on the example of saved fuel for the diesel generators. I presented a comparative analysis of two power supply system operations. The first variant includes photovoltaic panels, storage batteries and diesel generators. The second variant includes only diesel generators. Comparative analysis was carried out according to the amount of fuel consumption. So, the difference in total cost is 1.311 million rubles. Economy of fuel in

liters is 25 528. It means that the government could save only 1.311 mln rubles per year using PV power plant, but the whole investment for 20 years is 39.2 mln rubles. So, it takes about 30 years to cover all investments without any profit, but after 20 years it will be necessary to change equipment on new one that will require additional investment again. So, the project is not economic effective from the point of saving fuel costs also. But it was realistic scenario when both of consumption and fuel cost are according to expected value. And to make financial analysis better it is recommended to do other scenarios also, what has been done in the last seventh chapter.

In seventh chapter I did nine different scenarios, where combinations of realistic, pessimistic and optimistic fuel consumption with realistic, pessimistic and optimistic fuel were presented. I assumed that both of fuel price and fuel consumption could be less or more from the expected value on 20%. I obtained that depending on these changes, government could save more or less money, but it is still not enough to cover investments and to get profit. So, it is more profitable to use only diesel-generators.

To sum up, integration of photovoltaic power plant is not economic effective in that region, despite of midnight sun presence during three months. Investments are too huge to be covered by saved fuel expenses. My recommendation is to use only diesel-generators.

Bibliography and references


- [1] Subhes C. - Energy Economics: Concepts, Issues, Markets and Governance, Springer, 2011, ISBN: 0857292676.
- [2] Wikipedia. The free Encyclopedia. [Online]. Available: [https://ru.wikipedia.org/wiki/Хатанга_\(село\)](https://ru.wikipedia.org/wiki/Хатанга_(село))
- [3] “Pravila Ustroystva Elektroustanovok”. –7th Edition, 2002. – 330 p.
- [4] Wikipedia. The free Encyclopedia. [Online]. Available: https://ru.wikipedia.org/wiki/Полярная_ночь
- [5] “Solnechniy calculator” [Online]. Available: <http://www.hmn.ru>
- [6] “Raspisanie pogodi”. [Online]. Available: <https://rp5.ru/Хатанга>
- [7] “Diesel company”. [Online]. Available: <http://www.comd.ru/catalog/dizelnye-elektrostancii-tsena-DES/Professional/DGU-dizel-generatory-MMZ/dizelnaya-elektrostanciya-50-kvt-AD-50-T400-MMZ/automation-grades/>
- [8] “Federalniy zakon 261 ot 23.11.2009 “Ob energosberezhenii i o povishenii energeticheskoy effektivnosti i o vnesenii izmeneniy v otdelnie zakonodatelnie akti Rossiyskoy Federatsii”
- [9] Budzko I.A. i dr. “Elektrosnabzhenie selskogo khozyaistva”. – M.: Kolos, 2000. – 536p
- [10] “Nauchno-prikladnoy spravochnik po klimatu SSSR”. Seria 3. Vipusk 21. – L.: Gidrometeoizdat, 1990. – 312p
- [11] Samoylov D.V. “Rasshhet velichini postupleniya toploti ot solnechnoy radiatsii na poverhnost Zemli”: Metodicheskie ukazaniya/Pod red. Yu.V. Peshti. – M.: MGTU im. N.E. Baumana, 2006. – 20 p
- [12] Matthias Gunther “Advanced CSP Teaching Materials”. Chapter 2 “Solar Radiation”. [Online]. Available: <http://www.energy-science.org/bibliotheque/cours/1361469594Chapter%2002%20radiation.pdf>
- [13] Lukutin B.V. Surzhikova E.B. Shandarova E.B “Vozobnovlayemaya energetika v detsentralizovannom elektrosnabzhenii: Tomskiy Politekhnicheskii Universitet (TPU). — M: Ergoatomizdat, 2008. — 231 p
- [14] “Vash solnechniy dom” [Online]. Available: <http://shop.solarhome.ru/300w-hse300-72m-helios-solarworks-24v-mono.html>

- [15] Vissarionov V.I., Deryugina G.V., Kuznetsova V.A., Solar Power Engineering: Book for Higher Educational Institutions / Ed. by V.I.Vissarionov -M.: Publishing house MPEI, 2008. - 320p.
- [16] EXMORK [Online]. Available: <http://inventory.ru/product/akkumuljator-delta-dtm-12200>
- [17] MAP «Energia» [Online]. Available: http://www.solarhome.ru/inverter/ricHEL/combi_plus.htm
- [18] “SOLNECHNYE.RU” [Online]. Available: <http://www.solnechnye.ru/inventory-220v/vybor-invertora.htm>
- [19] MAP «Energia» [Online]. Available: http://www.invertor.ru/zzz/item/map_pro_48_20
- [20] Math Help Planet. [Online]. Available: <http://mathhelpplanet.com/static.php?p=pokazateli-effektivnosti-investitsionnogo-proekta>
- [21] R. A. Brealey, S. C. Myers, and F. Allen, Principles of Corporate Finance, 10th ed. McGraw-Hill/Irwin, 2010.
- [22] Investopedia. [Online]. Available: <https://www.investopedia.com/terms/n/npv.asp>
- [23] I. Welch, Corporate Finance, 3rd ed. Los Angeles, 2014.
- [24] Wikipedia. The free Encyclopedia. [Online]. Available: <https://en.wikipedia.org/wiki/Inflation>
- [25] Ministry of Economic Development of the Russian Federation. [Online]. Available: <http://economy.gov.ru/minec/about/structure/depMacro/20160506>.
- [26] H.K. Barker and G.E. Powell, Understanding Financial Management. 2007.
- [27] Financial analysis. [Online]. Available: <http://finzz.ru/stavka-diskontirovaniya.html>
- [28] “Postanovleniye Pravitelstva Rossiyskoy Federatsii №1470 Ob utverzhdenii poryadka predostavleniy gosudarstvennih garantiy na konkursnoy osnove za schet sredstv Budgeta razvitiy Rossiyskoy Federatsii”.
- [29] Wikipedia. Sensitivity analysis. [Online]. Available: https://en.wikipedia.org/wiki/Sensitivity_analysis.
- [30] Sputnik-georgia.ru. [Online]. Available: <https://sputnik-georgia.ru/spravka/20171208/238490310/Povyshenie-cen-na-benzin-v-2018-godu-prognoz-rosta-ceny-do-50-rublej.html>
- [31] H. K. Barker and G. E. Powell, Understanding Financial Management. 2007.


[32] "Diesel company". [Online]. Available: <https://www.comd.ru/catalog/dizelnye-elektrostancii-tsena-des/professional/dgu-dizel-generatory-mmz/dizelnaya-elektrostanciya-35-kvt-ad-35-t400-mmz-d-243/>

Appendices


Appendix A – Consumer load graphs




Picture A.1 – Graph of winter daily active power consumption (December)



Picture A.2 – Graph of spring daily active power consumption (March)




Picture A.3 – Graph of summer daily active power consumption (June)




Picture A.4 – Graph of autumn daily active power consumption (September)


Appendix B – Choice of accumulator batteries




Picture B.1 – Graph of daily active power consumption in May




Picture B.2 – Graph of daily active power consumption in June



Picture B.3 – Graph of load capacity and solar insolation in May




Picture B.4 – Graph of load capacity and solar insolation in June




Picture B.5 – Graph of load capacity and solar insolation in March

Solar insolation exceeds the load only from 10 a.m. to 13 p.m hours of the day. Therefore, the diesel generator can be switched off for 3 hours to save fuel.




Picture B.6 – Graph of load capacity and solar insolation in April

Solar insolation exceeds the load only from 9 a.m. to 16 p.m. hours of the day. Therefore, the diesel generator can be switched off for 8 hours to save fuel. Moreover 156.77 kWh can be stored and used in the future for another 4 hours. Thus, the diesel generator will be switched off from 9 a.m. to 9 p.m.




Picture B.7 – Graph of load capacity and solar insolation in July

Solar insolation exceeds the load only from 9 a.m. to 18 p.m. hours of the day. Therefore, the diesel generator can be switched off for 10 hours to save fuel. Moreover 172.97 kWh can be stored and used in the future for another 3 hours. Thus, the diesel generator will be switched off from 9 a.m. to 10 p.m.




Picture B.8 – Graph of load capacity and solar insolation in August

Solar insolation exceeds the load only from 10 a.m. to 15 p.m. hours of the day. Therefore, the diesel generator can be switched off for 6 hours to save fuel. Moreover 54.49 kWh can be stored and used in the future for another 2 hours. Thus, the diesel generator will be switched off from 10 a.m. to 18 p.m.



Picture B.9 – Graph of load capacity and solar insolation in September

Solar insolation is not enough to cover demand of electricity, so, diesel generator will not be switched off, and so, there is no fuel economy.



Picture B.10 – Graph of load capacity and solar insolation in October

Solar insolation is not enough to cover demand of electricity, so, diesel generator will not be switched off, and so, there is no fuel economy.

Appendix C – Results of Financial model

Table C1 – NPV of financial model with price of electricity 95 RUB

| | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|----------------|--------------|------------|-------------|-------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Investment | - 39 212 556 | | | | | | | | - 3 090 119 | | |
| Revenue | | 1 277 986 | 1 329 105 | 1 382 269 | 1 437 560 | 1 495 062 | 1 554 865 | 1 617 059 | 1 681 742 | 1 749 012 | 1 818 972 |
| Operation Cost | | - 392 126 | - 407 811 | - 424 123 | - 441 088 | - 458 731 | - 477 081 | - 496 164 | - 516 010 | - 536 651 | - 558 117 |
| Depreciation1 | | -1 960 628 | - 1 960 628 | - 1 960 628 | -1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 |
| Depreciation2 | | | | | | | | | | - 441 446 | - 441 446 |
| Depreciation3 | | | | | | | | | | | |
| TAX | | - | - | - | - | - | - | - | - | - | - |
| CF | - 39 212 556 | 885 860 | 921 294 | 958 146 | 996 472 | 1 036 331 | 1 077 784 | 1 120 896 | - 1 924 388 | 1 212 361 | 1 260 855 |
| | | | | | | | | | | | |
| NPV | - 42 777 902 | | | | | | | | | | |

Table C2 – Cash Flows of financial model with NPV = 0

| | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|----------------|--------------|------------|-------------|-------------|------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Investment | - 39 212 556 | | | | | | | | - 3 090 119 | | |
| Revenue | | 7 787 584 | 8 099 087 | 8 423 051 | 8 759 973 | 9 110 372 | 9 474 786 | 9 853 778 | 10 247 929 | 10 657 846 | 11 084 160 |
| Operation Cost | | - 392 126 | - 407 811 | - 424 123 | - 441 088 | - 458 731 | - 477 081 | - 496 164 | - 516 010 | - 536 651 | - 558 117 |
| Depreciation1 | | -1 960 628 | - 1 960 628 | - 1 960 628 | -1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 |
| Depreciation2 | | | | | | | | | | - 441 446 | - 441 446 |
| Depreciation3 | | | | | | | | | | | |
| TAX | | - | - | - | - | - | - | - | - | - | - |
| CF | - 39 212 556 | 7 395 458 | 7 691 277 | 7 998 928 | 8 318 885 | 8 651 640 | 8 997 706 | 9 357 614 | 6 641 799 | 10 121 195 | 10 526 043 |
| | | | | | | | | | | | |
| NPV | - 0 | | | | | | | | | | |

Continue of Table C3 - Cash Flows of financial model with NPV = 0

| 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 |
|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| - 919 670 | | | | - 4 066 386 | | | | | |
| 11 527 526 | 11 988 627 | 12 468 173 | 12 966 899 | 13 485 575 | 14 024 998 | 14 585 998 | 15 169 438 | 15 776 216 | 16 407 264 |
| - 580 442 | - 603 659 | - 627 806 | - 652 918 | - 679 035 | - 706 196 | - 734 444 | - 763 822 | - 794 374 | - 826 149 |
| - 1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 | - 1 960 628 |
| - 441 446 | - 441 446 | - 441 446 | - 441 446 | - 441 446 | - 441 446 | - 441 446 | - 441 446 | - 441 446 | - 441 446 |
| | - 91 967 | - 91 967 | - 91 967 | - 91 967 | - 91 967 | - 91 967 | - 91 967 | - 91 967 | - 91 967 |
| - | - | - | - | - | - | - | - | - | - |
| 10 027 415 | 11 384 968 | 11 840 367 | 12 313 982 | 8 740 154 | 13 318 802 | 13 851 555 | 14 405 617 | 14 981 841 | 15 581 115 |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

Appendix D

Table D.1 – Fuel consumption depending on realistic load

| Winter | P, kWh | g, g/kWh | G, kg/h | Spring | P, kWh | g, g/kWh | G, kg/h | Summer | P, kWh | g, g/kWh | G, kg/h | Autumn | P, kWh | g, g/kWh | G, kg/h |
|-------------------------|-----------|-------------|--------------|--------|-----------|-------------|--------------|--------|-----------|-------------|--------------|--------|-----------|-------------|---------------|
| | 25 | 290 | 7,25 | | 16 | 350 | 5,6 | | 14 | 370 | 5,18 | | 22,5 | 305 | 6,8625 |
| | 25 | 290 | 7,25 | | 20 | 310 | 6,2 | | 14 | 370 | 5,18 | | 22,5 | 305 | 6,8625 |
| | 25 | 290 | 7,25 | | 20 | 310 | 6,2 | | 14 | 370 | 5,18 | | 22,5 | 305 | 6,8625 |
| | 25 | 290 | 7,25 | | 20 | 310 | 6,2 | | 14 | 370 | 5,18 | | 22,5 | 305 | 6,8625 |
| | 25 | 290 | 7,25 | | 20 | 310 | 6,2 | | 17,5 | 340 | 5,95 | | 22,5 | 305 | 6,8625 |
| | 30 | 272 | 8,16 | | 20 | 310 | 6,2 | | 17,5 | 340 | 5,95 | | 31,5 | 270 | 8,505 |
| | 30 | 272 | 8,16 | | 24 | 290 | 6,96 | | 21 | 308 | 6,468 | | 40,5 | 259 | 10,489 |
| | 30 | 272 | 8,16 | | 24 | 290 | 6,96 | | 21 | 308 | 6,468 | | 49,5 | 290 | 14,355 |
| | 30 | 272 | 8,16 | | 24 | 290 | 6,96 | | 21 | 308 | 6,468 | | 36 | 264 | 9,504 |
| | 30 | 272 | 8,16 | | 24 | 290 | 6,96 | | 21 | 308 | 6,468 | | 27 | 285 | 7,695 |
| | 35 | 265 | 9,275 | | 24 | 290 | 6,96 | | 21 | 308 | 6,468 | | 27 | 285 | 7,695 |
| | 35 | 265 | 9,275 | | 24 | 290 | 6,96 | | 21 | 308 | 6,468 | | 31,5 | 270 | 8,505 |
| | 35 | 265 | 9,275 | | 24 | 290 | 6,96 | | 21 | 308 | 6,468 | | 36 | 264 | 9,504 |
| | 35 | 265 | 9,275 | | 28 | 275 | 7,7 | | 21 | 308 | 6,468 | | 27 | 285 | 7,695 |
| | 40 | 258 | 10,32 | | 28 | 275 | 7,7 | | 21 | 308 | 6,468 | | 27 | 285 | 7,695 |
| | 40 | 258 | 10,32 | | 32 | 270 | 8,64 | | 24,5 | 290 | 7,105 | | 27 | 285 | 7,695 |
| | 40 | 258 | 10,32 | | 32 | 270 | 8,64 | | 24,5 | 290 | 7,105 | | 27 | 285 | 7,695 |
| | 50 | 290 | 14,5 | | 32 | 270 | 8,64 | | 28 | 275 | 7,7 | | 36 | 264 | 9,504 |
| | 50 | 290 | 14,5 | | 36 | 264 | 9,504 | | 28 | 275 | 7,7 | | 63 | 270 | 17,01 |
| | 60 | 272 | 16,32 | | 40 | 259 | 10,36 | | 28 | 275 | 7,7 | | 90 | 259 | 23,31 |
| | 70 | 265 | 18,55 | | 40 | 259 | 10,36 | | 31,5 | 270 | 8,505 | | 76,5 | 260 | 19,89 |
| | 70 | 265 | 18,55 | | 40 | 259 | 10,36 | | 42 | 258 | 10,836 | | 54 | 285 | 15,39 |
| | 95 | 261 | 24,795 | | 56 | 262 | 14,672 | | 49 | 262 | 12,838 | | 36 | 262 | 9,432 |
| | 100 | 268 | 26,8 | | 80 | 259 | 20,72 | | 70 | 265 | 18,55 | | 27 | 285 | 7,695 |
| Totally | | | 279.1 | | | | 202,6 | | | | 178.9 | | | | 243,57 |
| Totally, l/h | | | 234 | | | | 242 | | | | 213 | | | | 290 |

Appendix E – Calculation results of scenarios

E.1 Realistic Cost of fuel and Optimistic fuel consumption

Table E.1.1 - The monthly consumption of fuel and its prices

| Month | Per day, l | Per month, l | Price, RUB | Total cost, RUB |
|----------------|------------|---------------|------------|------------------|
| January | 272 | 8432 | 52 | 438 464 |
| February | 272 | 7616 | 52 | 396 032 |
| March | 230 | 7130 | 52 | 370 760 |
| April | 230 | 6900 | 52 | 358 800 |
| May | 230 | 7130 | 52 | 370 760 |
| June | 218 | 6540 | 52 | 340 080 |
| July | 218 | 6758 | 52 | 351 416 |
| August | 218 | 6758 | 52 | 351 416 |
| September | 262 | 7860 | 52 | 408 720 |
| October | 262 | 8122 | 52 | 422 344 |
| November | 262 | 7860 | 52 | 408 720 |
| December | 272 | 8432 | 52 | 438 464 |
| Totally | - | 89 538 | 52 | 4 655 976 |

Table E.1.2 - Data of the fuel and energy savings due to the PV panels operating

| Month | Demand per month, kWh | Per month, l | Price, RUB | Total cost, RUB |
|----------------|-----------------------|---------------|------------|------------------|
| January | 25 544 | 8432 | 52 | 438 464 |
| February | 23 072 | 7616 | 52 | 396 032 |
| March | 12 918 | 6333 | 52 | 329 316 |
| April | 4 217 | 3612 | 52 | 187 824 |
| May | - | 0 | 52 | - |
| June | - | 0 | 52 | - |
| July | 44 | 3101 | 52 | 161 252 |
| August | 9 460 | 4602 | 52 | 239 304 |
| September | 16 884 | 7860 | 52 | 408 720 |
| October | 22 524 | 8122 | 52 | 422 344 |
| November | 23 520 | 7860 | 52 | 408 720 |
| December | 25 544 | 5841 | 52 | 303 732 |
| Totally | - | 63 379 | 52 | 3 295 708 |

E.2 Pessimistic Cost of fuel and Optimistic fuel consumption

Table E.2.1 - The monthly consumption of fuel and its prices

| Month | Per day, l | Per month, l | Price, RUB | Total cost, RUB |
|----------------|------------|---------------|------------|------------------|
| January | 272 | 8432 | 63 | 531 216 |
| February | 272 | 7616 | 63 | 479 808 |
| March | 230 | 7130 | 63 | 449 190 |
| April | 230 | 6900 | 63 | 434 700 |
| May | 230 | 7130 | 63 | 449 190 |
| June | 218 | 6540 | 63 | 412 020 |
| July | 218 | 6758 | 63 | 425 754 |
| August | 218 | 6758 | 63 | 425 754 |
| September | 262 | 7860 | 63 | 495 180 |
| October | 262 | 8122 | 63 | 511 686 |
| November | 262 | 7860 | 63 | 495 180 |
| December | 272 | 8432 | 63 | 531 216 |
| Totally | - | 89 538 | 63 | 5 640 894 |

Table E.2.2 - Data of the fuel and energy savings due to the PV panels operating

| Month | Demand per month, kWh | Per month, l | Price, RUB | Total cost, RUB |
|----------------|-----------------------|---------------|------------|------------------|
| January | 25 544 | 8432 | 63 | 531 216 |
| February | 23 072 | 7616 | 63 | 479 808 |
| March | 12 918 | 6333 | 63 | 398 979 |
| April | 4 217 | 3612 | 63 | 227 556 |
| May | - | 0 | 63 | - |
| June | - | 0 | 63 | - |
| July | 44 | 3101 | 63 | 195 363 |
| August | 9 460 | 4602 | 63 | 289 926 |
| September | 16 884 | 7860 | 63 | 495 180 |
| October | 22 524 | 8122 | 63 | 511 686 |
| November | 23 520 | 7860 | 63 | 495 180 |
| December | 25 544 | 5841 | 63 | 367 983 |
| Totally | - | 63 379 | 63 | 3 992 877 |

E.3 Optimistic Cost of fuel and Realistic fuel consumption

Table E.3.1 - The monthly consumption of fuel and its prices

| Month | Per day, l | Per month, l | Price, RUB | Total cost, RUB |
|----------------|------------|--------------|------------|------------------|
| January | 234 | 7254 | 42 | 304 668 |
| February | 234 | 6552 | 42 | 275 184 |
| March | 242 | 7502 | 42 | 315 084 |
| April | 242 | 7260 | 42 | 304 920 |
| May | 242 | 7502 | 42 | 315 084 |
| June | 213 | 6390 | 42 | 268 380 |
| July | 213 | 6603 | 42 | 277 326 |
| August | 213 | 6603 | 42 | 277 326 |
| September | 290 | 8700 | 42 | 365 400 |
| October | 290 | 8990 | 42 | 377 580 |
| November | 290 | 8990 | 42 | 377 580 |
| December | 234 | 7254 | 42 | 304 668 |
| Totally | - | 89600 | 42 | 3 763 200 |

Table E.3.2 - Data of the fuel and energy savings due to the PV panels operating

| Month | Demand per month, kWh | Per month, l | Price, RUB | Total cost, RUB |
|----------------|-----------------------|--------------|------------|------------------|
| January | 31 930 | 7254 | 42 | 304 668 |
| February | 28 840 | 6552 | 42 | 275 184 |
| March | 16 147 | 6704 | 42 | 281 568 |
| April | 5 271 | 3216 | 42 | 135 072 |
| May | - | 0 | 42 | - |
| June | - | 0 | 42 | - |
| July | 4 871 | 2042 | 42 | 85 764 |
| August | 11 825 | 4670 | 42 | 196 140 |
| September | 21 105 | 8700 | 42 | 365 400 |
| October | 28 154 | 8990 | 42 | 377 580 |
| November | 29 400 | 8990 | 42 | 377 580 |
| December | 31 930 | 7254 | 42 | 304 668 |
| Totally | - | 64372 | 42 | 2 703 624 |

E.4 Pessimistic Cost of fuel and Realistic fuel consumption

Table E.4.1 - The monthly consumption of fuel and its prices

| Month | Per day, l | Per month, l | Price, RUB | Total cost, RUB |
|----------------|------------|--------------|------------|------------------|
| January | 234 | 7254 | 63 | 457 002 |
| February | 234 | 6552 | 63 | 412 776 |
| March | 242 | 7502 | 63 | 472 626 |
| April | 242 | 7260 | 63 | 457 380 |
| May | 242 | 7502 | 63 | 472 626 |
| June | 213 | 6390 | 63 | 402 570 |
| July | 213 | 6603 | 63 | 415 989 |
| August | 213 | 6603 | 63 | 415 989 |
| September | 290 | 8700 | 63 | 548 100 |
| October | 290 | 8990 | 63 | 566 370 |
| November | 290 | 8990 | 63 | 566 370 |
| December | 234 | 7254 | 63 | 457 002 |
| Totally | - | 89600 | 63 | 5 644 800 |

Table E.4.2 - Data of the fuel and energy savings due to the PV panels operating

| Month | Demand per month, kWh | Per month, l | Price, RUB | Total cost, RUB |
|----------------|-----------------------|--------------|------------|------------------|
| January | 31 930 | 7254 | 63 | 457 002 |
| February | 28 840 | 6552 | 63 | 412 776 |
| March | 16 147 | 6704 | 63 | 422 352 |
| April | 5 271 | 3216 | 63 | 202 608 |
| May | - | 0 | 63 | - |
| June | - | 0 | 63 | - |
| July | 4 871 | 2042 | 63 | 128 646 |
| August | 11 825 | 4670 | 63 | 294 210 |
| September | 21 105 | 8700 | 63 | 548 100 |
| October | 28 154 | 8990 | 63 | 566 370 |
| November | 29 400 | 8990 | 63 | 566 370 |
| December | 31 930 | 7254 | 63 | 457 002 |
| Totally | - | 64372 | 63 | 4 055 436 |

E.5 Optimistic Cost of fuel and Pessimistic fuel consumption

Table E.5.1 - The monthly consumption of fuel and its prices

| Month | Per day, l | Per month, l | Price, RUB | Total cost, RUB |
|----------------|------------|----------------|------------|------------------|
| January | 392 | 12152 | 42 | 510 384 |
| February | 392 | 10976 | 42 | 460 992 |
| March | 290 | 8990 | 42 | 377 580 |
| April | 290 | 8700 | 42 | 365 400 |
| May | 290 | 8990 | 42 | 377 580 |
| June | 253 | 7590 | 42 | 318 780 |
| July | 253 | 7843 | 42 | 329 406 |
| August | 253 | 7843 | 42 | 329 406 |
| September | 338 | 10140 | 42 | 425 880 |
| October | 338 | 10478 | 42 | 440 076 |
| November | 338 | 10140 | 42 | 425 880 |
| December | 392 | 12152 | 42 | 510 384 |
| Totally | - | 115 994 | 42 | 4 871 748 |

Table E.5.2 - Data of the fuel and energy savings due to the PV panels operating

| Month | Demand per month, kWh | Per month, l | Price, RUB | Total cost, RUB |
|----------------|-----------------------|---------------|------------|------------------|
| January | 38 316 | 12152 | 42 | 510 384 |
| February | 34 608 | 10976 | 42 | 460 992 |
| March | 20 661 | 8468 | 42 | 355 656 |
| April | 9 092 | 5549 | 42 | 233 058 |
| May | 2 520 | 2377 | 42 | 99 834 |
| June | 2 673 | 1669 | 42 | 70 098 |
| July | 9 698 | 4449 | 42 | 186 858 |
| August | 16 652 | 7480 | 42 | 314 160 |
| September | 25 326 | 10140 | 42 | 425 880 |
| October | 33 785 | 10478 | 42 | 440 076 |
| November | 35 280 | 10140 | 42 | 425 880 |
| December | 38 316 | 12152 | 42 | 510 384 |
| Totally | - | 96 030 | 42 | 4 033 260 |

E.6 Realistic Cost of fuel and Pessimistic fuel consumption

Table E.6.1 - The monthly consumption of fuel and its prices

| Month | Per day, l | Per month, l | Price, RUB | Total cost, RUB |
|----------------|------------|----------------|------------|------------------|
| January | 392 | 12152 | 52 | 631 904 |
| February | 392 | 10976 | 52 | 570 752 |
| March | 290 | 8990 | 52 | 467 480 |
| April | 290 | 8700 | 52 | 452 400 |
| May | 290 | 8990 | 52 | 467 480 |
| June | 253 | 7590 | 52 | 394 680 |
| July | 253 | 7843 | 52 | 407 836 |
| August | 253 | 7843 | 52 | 407 836 |
| September | 338 | 10140 | 52 | 527 280 |
| October | 338 | 10478 | 52 | 544 856 |
| November | 338 | 10140 | 52 | 527 280 |
| December | 392 | 12152 | 52 | 631 904 |
| Totally | - | 115 994 | 52 | 6 031 688 |

Table E.6.2 - Data of the fuel and energy savings due to the PV panels operating

| Month | Demand per month, kWh | Per month, l | Price, RUB | Total cost, RUB |
|----------------|-----------------------|---------------|------------|------------------|
| January | 38 316 | 12152 | 52 | 631 904 |
| February | 34 608 | 10976 | 52 | 570 752 |
| March | 20 661 | 8468 | 52 | 440 336 |
| April | 9 092 | 5549 | 52 | 288 548 |
| May | 2 520 | 2377 | 52 | 123 604 |
| June | 2 673 | 1669 | 52 | 86 788 |
| July | 9 698 | 4449 | 52 | 231 348 |
| August | 16 652 | 7480 | 52 | 388 960 |
| September | 25 326 | 10140 | 52 | 527 280 |
| October | 33 785 | 10478 | 52 | 544 856 |
| November | 35 280 | 10140 | 52 | 527 280 |
| December | 38 316 | 12152 | 52 | 631 904 |
| Totally | - | 96 030 | 52 | 4 993 560 |