

Tepelné ztráty vyhodnocení

	Místnost	Ztráta prostupem	Ztráta větráním za 18 °C na 22 °C	Zisk	Ztráta
	[-]	[W]	[W]	[W]	[W]
1.PP	S1.1.7	566	215	2064	-1283
	S1.1.8	902	215	685	433
	S1.1.9	888	215	689	414
	S1.1.10	1154	310	100	1363
	S1.1.11	815	242	1105	-48
	S1.1.12	467	215	986	-304
	S1.1.23	809	862	1780	-109
	S1.1.24	1297	269	2567	-1000
	S1.1.25	3666	0	2660	1006
	S1.1.33	1396	242	792	846
S1.1.43	112	67	2570	-2391	
1.NP	1.1.2	3231	485	2369	1347
	1.1.6	770	108	615	263
	1.1.14	852	215	1823	-756
	1.1.15	672	215	1889	-1002
	1.1.19	758	215	1884	-911
	1.1.20	645	215	1906	-1046
2NP	2.1.10	520	296	422	394
	2.1.11	1352	310	582	1080
	2.1.13	1485	310	498	1297
	2.1.15	856	310	464	702
	2.1.17	877	215	608	484
	2.1.18	549	215	1745	-980
	2.1.19	877	215	633	459
	2.1.20	877	215	1794	-702
	2.1.21	893	215	538	570
2.1.22	633	215	575	273	